

UR STENCILING REQUIREMENTS

DESCRIPTION	STENCIL WORDING
FIRE WALLS	FW-2HR FW-3HR
FIRE BARRIERS (EXIT ENCLOSURE HORIZONTAL EXIT INCIDENTAL USE/HAZARD OCCUPANCY SEPARATION)	FB-1HR FB-2HR
SHAFT ENCLOSURES (FIRE BARRIER AT ELEVATOR, STAIR OR MECHANICAL SHAFT)	SE-1HR SE-2HR
FIRE PARTITION (ELEV LOBBY, CORRIDOR WALL, TENANT SEPARATION)	FP-1HR
SMOKE BARRIERS (1 HOUR RATED AT OTHER OCCUPANCIES)	SB-1HR
FIRE BARRIER / SMOKE BARRIERS (SMOKE BARRIER COINCIDING W/FIRE BARRIER - INCIDENTAL USE, EXIT ENCLOSURE, ETC.)	FBSB-1HR FBSB-2HR
SHAFT ENCLOSURE / SMOKE BARRIERS (SMOKE BARRIER COINCIDING W/SHAFT ENCLOSURE)	SESB-1HR SESB-2HR
FIRE WALL / SMOKE BARRIERS (SMOKE BARRIER COINCIDING W/FIRE WALL)	FWSB-1HR FWSB-2HR
SMOKE PARTITIONS (SP) (UNRATED SMOKE RESISTANT CONSTRUCTION - CORRIDOR)	SP-0HR
HORIZONTAL ASSEMBLIES (HA) (RATED ENGINEERED CEILINGS)	HA-1HR HA-2HR
NON - RATED WALLS	NR

UR STENCILING REQUIREMENTS (12/18/13)